

Test Report
Readymade Plaster

Customer Name : R. D. Ventures

Office address : 10, Hermes Minor, Ramwadi (Nagar Road),
Wadgaon Sheri, Pune-411006

Description : Readymade Plaster (Sample ID-Enovplast)

Issue Date : 19-Aug-2013

Record No. : OT-1997/1-1

Sample Ref. No. : OT-74410

Bill No. : DT - 21208

Received Date : 17-July-2013

Testing Date : 18-Aug-2013


OBSERVATION & CALCULATIONS :

Sr. No	Name of test	Result	Unit	Specified	Method of testing
1	3 Days Compressive Strength	2.0	N/mm ²	-----	IS:2250-1981
2	7 Days Compressive Strength	3.0	N/mm ²	-----	IS:2250-1981
3	28 Days Compressive Strength	8.0	N/mm ²	-----	IS:2250-1981

Notes:

- 1)The test reports and results relate to the particular specimen/sample(s) of the material as delivered/received and tested in the laboratory.
- 2)Any test report shall not be reproduced except in full,without the written permission from Durocrete.

Authorized Signatory


Vishwas Kulkarni
(Manager Technical)

For all technical queries contact (020) 24348027.

---End of report---

Checked By :Anant Gaiwad

