

An ISO / IEC 17025:2017 Accredited Testing Laboratory

Test Report

Ready Mix Plaster Physical

Customer Name : R. D. Ventures
Office Address : 01, Samarth Terrace, Near Airforce Station Gate, Vimannagar, Pune 411014
Site Name (*) : R. D Ventures
Description (*) : Envoplast Plaster
Supplier Name : -
Contact Details : Mr. Kattal Ahemad Kazi - 7499027978 (Route : R5)

Testing Location : PUNE LAB
Material Code : OT
Sample Ref No. : 156667
Report No. : OT-11732/2-1
Bill No : 202425PUN1012
Date of Mat. Recd : 29-Apr-2024
Date of Testing : 28-May-2024
Date of Issue : 30-May-2024

OBSERVATIONS & CALCULATIONS :

Sr no.	Name of Test	Unit	Test Result
1	Water Demand	%	13.6
2	Pull off test (28 Days)	N/mm ²	0.32
3	Compressive Strength Test (3 Days)	N/mm ²	5.79
4	Compressive Strength Test (7 Days)	N/mm ²	6.89
5	Compressive Strength Test (28 Days)	N/mm ²	9.46

References :

- 1) IS : 2250-1981 Test Method for Masonry Mortar
- 2) BS EN 1015 Methods of test for mortar for masonry (a multi part standard)

Remarks :

- 1) The Indian Standard for the materials mentioned above does not specify particular acceptance limits; therefore, the results of testing should be compared with the Material Test Certificate provided by the supplier or manufacturer

Notes :

- 1) (*) indicates- Information has been provided by client.
- 2) Sampling has been carried out by client. DESPL is not responsible for sampling criteria.
- 3) Simple acceptance decision rule is applied as per ILAC G8 for the above conducted test.
- 4) The test reports and results relate to the particular specimen/sample(s) of the material as delivered/received and tested in the laboratory.
- 5) Any test report shall not be reproduced except in full, without the written permission from Durocrete.

This report can be authenticated on our website www.durocrete.in

Authorized Signatory



Neeta Nivangune
(Sr. Manager – Lab Operations)

Checked by : Shivhar Chate

--End of Report--